



CB TEST CERTIFICATE

Ref. Certificate No.

NL-20336

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Switch disconnecter		
Applicant:	LS Industrial Systems Co., Ltd.	1026-6, Hogye-dong, Dong-an-gu Anyang-si, Gyeonggi-do	Korea, Republic of
Manufacturer:	LS Industrial Systems Co., Ltd.	1026-6, Hogye-dong, Dong-an-gu Anyang-si, Gyeonggi-do	Korea, Republic of
Factory:	LS Industrial Systems Co., Ltd.	1026-6, Hogye-dong, Dong-an-gu Anyang-si, Gyeonggi-do	Korea, Republic of
Rating and principal characteristics:	3P/3P+N; Ue = 690 V; Ie = 1000, 1250, 1600 A; AC-23B; Uimp = 8 kV; Ui = 1000 V; Icw = 25 kA – 1 s; Icm = 52,5 kA; IP30; 50/60 Hz		
Trade mark (if any):	LS		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	TS1000NA, TS1250NA, TS1600NA		
Additional information:	-		
Sample of product tested to be in conformity with IEC:	60947-3(ed.3)		
Test Report Ref. No:	2131728.52		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2011-04-19

 **DEKRA**
DEKRA Certification is
former KEMA Quality