



CB TEST CERTIFICATE

Ref. Certificate No.

NL-13143/A1

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Switch Disconnecter		
Applicant:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Manufacturer:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Factory:	LSIS Co., Ltd. CheongJu Plant	95, Baekbong-ro, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do	Korea, Republic of
Rating and principal characteristics:	3/4 pole Switch Disconnecter In = 800 A Utilisation category = AC-23A Ue = 460 Vac Ui = 750 Vac Icw = 9,6 kA/3s Icm = 16,3 kA Uimp = 8 kV Rated frequency = 50/60 Hz		
Trade mark (if any):	LS		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	TS800NA		
Additional information:	Renewal of certificate. Originally tested in 2007. Product compliant with EN 60947-3		
Sample of product tested to be in conformity with IEC:	60947-3(ed.2);am1		
Test Report Ref. No:	2107133.55 and 2168756.69		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2015-01-28

