



CB TEST CERTIFICATE

Ref. Certificate No.

NL-19284/A1

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Instantaneous trip circuit breaker (ICB)		
Applicant:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Manufacturer:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Factory:	LSIS Co., Ltd. Cheongju Plant	95, Baekbong-ro, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do	Korea, Republic of
Rating and principal characteristics:	3 pole ICB $I_e = 630 \text{ A}$ $U_i = 750 \text{ Vac}$, $U_{imp} = 8 \text{ kV}$ $I_{cs} = I_{cu} = 200 \text{ kA-220\&240 V}$, $150 \text{ kA-380\&415 V}$, $130 \text{ kA-440\&460 V}$, 85 kA 480\&500 V Rated frequency = 50 / 60 Hz		
Trade mark (if any):	LS		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	TS800 E/N/S/H/P/L		
Additional information:	Renewal of certificate. Product compliant with EN 60947-2. MCCB Recertified under NL-34652 and according annex O, no additional test are required		
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1;am2		
Test Report Ref. No:	2138116.52 (dated 2010-10-21)		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2015-03-10

