



CB TEST CERTIFICATE

Ref. Certificate No.

NL-33643

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.
Product:	Moulded case circuit-breaker (earth leakage circuit breaker)
Applicant:	LSIS Co., Ltd. 127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do Korea, Republic of
Manufacturer:	LSIS Co., Ltd. 127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do Korea, Republic of
Factory:	LSIS Co., Ltd. Cheongju Plant 95, Baekbong-ro, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do Korea, Republic of
Rating and principal characteristics:	2, 3 and 4 pole MCCB (thermal/magnetic) 50/60 Hz, Cat A, Ui 750 V, Uimp 8 kV, Ics=Icu. See also first pages of test reports.
Trade mark (if any):	LS
Type of Manufacturer's Testing Laboratories used:	WMT
Model/Type reference:	TD100E/N/S/H/P/L, TD160E/N/S/H/P/L
Additional information:	This CB is re-issued due to change of standard. It replaces NL-10143/A1 dated 2006-03-21 product also compliant with EN 60947-2.
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1;am2
Test Report Ref. No:	2088503.50, .54, 2086029.50 (dated 2006-03-21), 2168756.50, -.51, -.52

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2014-11-25

