



CB TEST CERTIFICATE

Ref. Certificate No.

NL-18958/A1

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Instantaneous trip circuit breaker (ICB)		
Applicant:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Manufacturer:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Factory:	LSIS Co., Ltd. CheongJu Plant	95, Baekbong-ro, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do	Korea, Republic of
Rating and principal characteristics:	3 pole ICB I _e = 100 A, 160 A, 220 A U _i = 750 Vac; U _{imp} = 8 kV; I _{cu} = I _{cs} = 200 kA-220&240 V, 150 kA-380&415 V, 130 kA-440&460 V, 85 kA-480&500 V Rated frequency = 50 / 60 Hz		
Trade mark (if any):	LS		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	TS100E/N/S/H/P/L; TS160E/N/S/H/P/L; TS250E/N/S/H/P/L;		
Additional information:	Renewal of certificate. Product compliant with EN 60947-2 MCCB. Recertified under NL-34652 and according annex O, no additional tests are required		
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1;am2		
Test Report Ref. No:	2138116.50 (dated 2010-08-26)		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2015-03-10

