



CB TEST CERTIFICATE

Ref. Certificate No.

NL-34652

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Moulded case circuit breaker		
Applicant:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Manufacturer:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Factory:	LSIS Co., Ltd. Cheongju Plant	95, Baekbong-ro, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do	Korea, Republic of
Rating and principal characteristics:	2, 3, 4 pole MCCB (with Neutral on either right or left side) Electronic trip unit (ETM, ETS) or thermal magnetic Ue = 220, 240, 380, 415, 500 V. Ui = 750 Vac Uimp = 8 kV Ics = Icu Rated frequency = 50/60 Hz Cat A. See also first pages of test reports		
Trade mark (if any):	LS		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	TS100 E/N/S/H/P/L, TS160 E/N/S/H/P/L, TS250 E/N/S/H/P/L, TS400 E/N/S/H/P/L, TS630 E/N/S/H/P/L, TS800 E/N/S/H/P/L		
Additional information:	Renewal by spot check, replaces NL-10143/A1, NL-11135/A2, NL-18443. Product compliant with EN 60947-2		
Sample of product tested to be in conformity with IEC:	60947-2(ed.4);am1;am2		
Test Report Ref. No:	2131824.50, -51, -52, 2168756.54 up to -57, 2168756.60 up to -63, 2168756.65 up to -68		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands



Signed by: F.S. Strikwerda

Date of issue: 2015-01-28