



CB TEST CERTIFICATE

Ref. Certificate No.

NL-33645

IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Moulded case circuit-breaker (earth leakage circuit breaker)		
Applicant:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Manufacturer:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Factory:	LSIS Co., Ltd. Cheongju Plant	95, Baekbong-ro, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do	Korea, Republic of
Rating and principal characteristics:	3/4 pole Switch Disconnector In = 100, 160 A Utilisation category = AC-23 A Ue = 460 Vac Ui = 750 Vac Icw = 2,2 kA/3s Icm = 3,1 kA Uimp = 8 kV Rated frequency = 50/60 Hz		
Trade mark (if any):	LS		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	TD100NA, TD160NA		
Additional information:	This certificate replaces NL-13140 (dated 2007-08-29) and is re-issued due to change of standard.		
Sample of product tested to be in conformity with IEC:	60947-3(ed.3);am1		
Test Report Ref. No:	2107133.52 (dated August 2007) and 2168756.53		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.
Meander 1051, 6825 MJ
Arnhem
The Netherlands

Signed by: H.R.M. Barends

Date of issue: 2014-11-25

