



## CB TEST CERTIFICATE

Ref. Certificate No.

NL-20336/A1

### IEC SYSTEM OF CONFORMITY ASSESSMENT SCHEMES FOR ELECTROTECHNICAL EQUIPMENT AND COMPONENTS (IECEE) CB SCHEME

Issued by:	DEKRA Certification B.V.		
Product:	Switch disconnecter		
Applicant:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Manufacturer:	LSIS Co., Ltd.	127, LS-ro, Dongan-gu, Anyang-si, Gyeonggi-do	Korea, Republic of
Factory:	LSIS Co., Ltd. Cheongju Plant	95, Baekbong-ro, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do	Korea, Republic of
Rating and principal characteristics:	3P/3P+N; Ue = 690 V; Ie = 1000, 1250, 1600 A; AC-23B; Uimp = 8 kV; Ui = 1000 V; Icw = 25 kA – 1 s; Icm = 52,5 kA; IP30; 50/60 Hz		
Trade mark (if any):	LS		
Type of Manufacturer's Testing Laboratories used:	WMT		
Model/Type reference:	TS1000NA, TS1250NA, TS1600NA		
Additional information:	Renewal of certificate. Originally tested in 2011. Product compliant with EN 60947-3		
Sample of product tested to be in conformity with IEC:	60947-3(ed.3);am1		
Test Report Ref. No:	2131728.52 and 2168656.72		

This CB Test Certificate is issued by the National Certification Body:

DEKRA Certification B.V.  
Meander 1051, 6825 MJ  
Arnhem  
The Netherlands

Signed by: F.S.Strikwerda

Date of issue: 2015-01-28

